

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE



LISTING No. 7165-0559:160

Page 1 of 2

CATEGORY: Fire Alarm Control Unit (Commercial)

LISTEE: Silent Knight Security, 7550 Meridian Circle, Maple Grove, MN 55369
Contact: Michael Mc Isaac (763) 493-6400 Fax (763) 391-5464
Mike.mcisaac@honeywell.com

DESIGN: Models IFP-2000-VIP Fire Alarm Control Units. Power limited, automatic, manual, waterflow, sprinkler supervisory, local, emergency Communication and Relocation, remote station (PPU), central station (PPU) services. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

IFP-2000 VIP	Control Unit
RPS-2000	Power Expander/Supply
RA-2000	Annunciator
5220	Polarity Reversal Module
5496	Intelligent Power Module
5815XL	SLC Expander Module
5824	Printer Interface
5865-3/5965-4	LED Annunciator
5880	LED IO Module
5883	Relay Interface Module
IFP-RPT	Network repeater
IDP-Relay	Relay Module
RBB	Battery Box
VIP-50	50W Amplifier
VIP-VCM	Voice Control Module
VIP-SW16	LED Annunciator
VIP-CE4	Speaker Expander Module
VIP-RM	Remote Microphone Module

RATING: 120 VAC Primary, 24 VDC Secondary

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

12-01-08 bh

APPROVAL: Listed as commercial fire alarm control unit for use with separately listed initiating and indicating devices. Refer to listee's Installation Instruction Manual for details.

This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition and meets the requirements of UL Standard 864, 9th Edition.

NOTE: Suitable for high-rise application when used in conjunction with VIP-50 Amplifier and VIP-VCM Voice Control Module, two-way firefighter telephone.

12-01-08 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **DECEMBER 4, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**
Fire Engineering Division